Area Source, Existing, NESHAP ZZZZ Engine Requirements

Compliance Dates: CI - 5/3/13 SI - 10/19/13

Records: Keep records for 5 yrs that show compliance (notifications, reports, tests, maintenance, etc)

	НР	CI/Diesel	2-Stroke Lean Burn	4-Stroke Lean Burn	4-Stroke Rich Burn	4SLB & 4SRB, ≤24hrs/yr	4SLB & 4SRB, Remote RICE	Landfill & Digester Gas	Emergency & Black Start
3	hp < 100	b	b	b	b	-	-	b	b
2	100 ≤ hp ≤ 300	b	b	b	b	-	-	b	b
	300 < hp ≤ 500	a (no Initial Notification)	b	b	b	-	-	b	b
	> 500	a	b	a	a	b	b	b	b, c

- Initial Notification, Notice of Performance Test (60 days before), Notification of Compliance Status (within 60 days of test), Semiannual Compliance Report (annual if operates < 100hrs/yr).
- **b** Deviation Report (only if a deviation from NESHAP ZZZZ requirements occurs).
- c Annual Report (if operated or is contractually obligated to operate > 15 hrs/yr via an allowable power supply agreement).

НР	CI/Diesel	2-Stroke Lean Burn	4-Stroke Lean Burn	4-Stroke Rich Burn	4SLB & 4SRB, ≤24hrs/yr	4SLB & 4SRB, Remote RICE	Landfill & Digester Gas	Emergency & Black Start
hp < 100	none	none	none	none	-	-	none	none
100 ≤ hp ≤ 300	none	none	none	none	-	-	none	none
300 < hp ≤ 500	49 ppm CO or 70% CO↓, d	none	none	none	-	-	none	none
> 500	23 ppm CO or 70% CO↓, e	none	47 ppm CO or 93% CO↓, f	270 ppm CO or reduction, g	none	none	none	none

- d 49 ppm CO limit or 70% CO reduction; initial performance test only (due by 10/30/2013).
 - e 23 ppm CO limit or 70% CO reduction; initial performance test (due by 10/30/2013), then subsequent performance tests every 8,760 hrs or 3 yrs, whichever comes first (5 yrs. if operates < 100hrs/yr).
- Install oxidation catalyst; 47 ppm CO limit or 93% CO reduction; initial performance test (due by 4/17/2014), then conduct annual compliance demonstration
- Install non-selective catalytic reduction; 270 ppm CO limit, or 75% CO reduction, or 30% THC reduction; initial performance test (due by 4/17/2014), then conduct annual compliance demonstration.

	НР	CI/Diesel	2-Stroke Lean Burn	4-Stroke Lean Burn	4-Stroke Rich Burn	4SLB & 4SRB, ≤24hrs/yr	4SLB & 4SRB, Remote RICE	Landfill & Digester Gas	Emergency & Black Start
ſ	hp < 100	h, o	h, q	h, p	h, p	-	-	h, p	h, r, t
	100 ≤ hp ≤ 300	h, o	h, q	h, p	h, p	-	-	h, p	h, r, t
	300 < hp ≤ 500	h, i, j	h, q	h, p	h, p	-	-	h, p	h, r, t
1	> 500	h, i, j, k, l	h, q	h, m	h, n	h, r	h, s	h, p	h, r, t

- h Mimize idle time during startup (startup not to exceed 30 mins), then normal emission standards apply.
 - i CARB diesel fuel required if displacement < 30 liters per cylinder.
- j Operate a closed crankcase ventilation system or open crankcase filtration emission control system per manufacturer's requirements.
- k If catalyst is installed, catalyst pressure drop ≤ 2 inH₂O different than measured @ initial performance test; & measure monthly.
 - If catalyst is installed, 450°F < catalyst inlet temperature < 1,350°F; continuously monitored; & conduct annual system audit.
- m Auto engine shut down @ 1,350°F; or 450°F < catalyst inlet temperature < 1,350°F, continuously monitored, and conduct annual system audit.
- n Auto engine shut down @ 1,250°F; or 750°F < catalyst inlet temperature < 1,250°F, continuously monitored, and conduct annual system audit.
- Change engine oil & filter and inspect air cleaner every 1,000 hrs and inspect/replace as necessary all hoses & belts every 500 hrs, or annually
- (whichever comes first).
- Change engine oil & filter, inspect spark plugs, and inspect/replace as necessary all hoses & belts every 1,440 hrs, or annually (whichever comes first).
- Change engine oil & filter, inspect spark plugs, and inspect/replace as necessary all hoses & belts every 4,320 hrs, or annually (whichever comes first).
- Change engine oil & filter and inspect/replace as necessary all hoses & belts every 500 hrs and inspect air cleaner or spark plug every 1,000 hrs, or annually (whichever comes first).
- Change engine oil & filter, inspect spark plugs, and inspect/replace as necessary all hoses & belts every 2,160 hrs, or annually (whichever comes first).
- t Install a non-resettable hour meter.

Notifications & Reports